

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0328:0511 Page 1 of 2

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO 63042 United States
Contact: Brad Serangeli (314) 595-6900 Fax (314) 595-6999
Email: brads@pottersignal.com

DESIGN: Potter Model PFC - 4064 fire alarm control panel, Model CA-4064 Expander, Model IDC Expander. Automatic, Manual, waterflow and sprinkler supervisory type device and local, auxiliary, remote station (PPU), proprietary (PPU) and central station (PPU) services.

System components:
PFC - 4064 Mainboard panel assembly
CA - 4064 Class A expander card
RA - 6500, RA - 6500R, RA - 6500F LCD remote annunciator
UD - 1000 DACT
PSN - 1000 Power supply expander
IDC - 6 Initiating device expander card
LED - 16/16F LED Annunciator
DRV - 50 LED driver
RLY - 5 Relay expander card
FCB - 1000Fiber interface bridge
SPG - 1000 Serial/Parallel printer card
MC - 1000 Multi-connector module
3005013 EOLR
3005012 EOLR Diode

Refer to listee's Installation Instruction Manual for details.

RATING: Primary Operating Supply:
120/240 VAC
2.5A

Secondary Operating Supply
27.3 VDC
1.0 A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, rating and UL label.

APPROVAL: Listed as fire alarm control units when use with separately listed electrically and functionally

03-12-2018 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**

Fire Engineering Division

compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.

03-12-2018 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**

Fire Engineering Division