

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

Page 1 of 1

**LISTING No.** 7165-0328:0195

**CATEGORY:** 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

**LISTEE:** Potter Electric Signal Co1609 Park 370 Place, Hazelwood, MO 63042 United States  
Contact: Brad Serangeli (314) 595-6900 Fax (314) 595-6999  
Email: brads@pottersignal.com

**DESIGN:** Models P100, P200, P300, PFC-6030, PFC-6075, PFC-6075R and PFC-6200 fire alarm control units. Automatic, Manual, waterflow and sprinkler supervisory type device and local, auxiliary, releasing, remote station (PPU), proprietary (PPU) and central station (PPU) services. Refer to listee's Installation Instruction Manual for details. System components:

CA-6075: Class A Expander  
UD-1000: DACT  
3006460, 3006456, 3006467: Main Boards  
RA-6075, RA-6075R, RA-6500: Remote Annunciators  
3005013, 3005012: EOL Resistors  
PSN-1000, PSN-1000(E): Fire Power Expander  
\*Models AE-8, AE-14; Power expander enclosures  
SLCE-127: Loop Expander

**RATING:** 24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation, rating and UL label.

**APPROVAL:** Listed as fire alarm control units when use with separately listed electrically and functionally compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.

Units meet the requirements of UL Standard 864, 9th edition.

\*Rev. 05-01-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**  
*Fire Engineering Division*