

Certificate



Certificate no.

CU 72101414 01

License Holder:

American Power Conversion
Holding Inc.
3F No. 205, Sec. 3, Beishin Rd.
231 Shindian City, Taipei
Taiwan - R.O.C.

Manufacturing Plant:

International Precision
Assemblies, Inc. Plant 2
Lot 2 Blk 17, Phase IV Peza
4106 Rosario Cavite
Philippines

Test report no.: USA-DS 31081589 001

Client Reference: Ms. Delia Lee

Tested to: UL 1778:1994 (R1.00)
CSA C22.2.107.1-01

Certified Product: Uninterruptible Power Supply Equipment

License Fee - Units

Model Designation: 1) BK500XXXXXXXX 2) BK350XXXXXXXX 7
3) NEC500JP 4) NEC350JP
(X=0-9, a-z, A-Z, +, *, #, _, - or blank)

Rated Voltage: 1,2) AC 100V or AC 120V, 50/60Hz
3,4) AC 100V, 50/60Hz

Rated Current: 1-4) 10A

Protection Class: I contd.

7

Appendix: 1, 1-5

Licensed Test mark:



Signature

Dipl.-Ing. A. Klinker
QA Certification Officer

Date of Issue
(day/mo/yr)
07/06/2010

Certificate



Certificate no.

CU 72101414 02

License Holder:

American Power Conversion
Holding Inc.
3F No. 205, Sec. 3, Beishin Rd.
231 Shindian City, Taipei
Taiwan - R.O.C.

Manufacturing Plant:

American Power Conversion
(India) Pvt., Ltd.
187/3 & 188/3, Jigani
562 106 Anekal, Bangalore
India

Test report no.: USA-DS 31081589 001

Client Reference: Ms. Delia Lee

Tested to: UL 1778:1994 (R1.00)
CSA C22.2.107.1-01

Certified Product: Uninterruptible Power Supply Equipment

License Fee - Units

contd.

Output Ratings: 1) AC 100V; 5A; 50/60Hz; 300W; 500VA or
AC 120V; 4.2A; 50/60Hz; 300W; 500VA
2) AC 100V; 3.5A; 50/60Hz; 210W; 350VA or
AC 120V; 2.9A; 50/60Hz; 240W; 350VA
3) AC 100V; 5A; 50/60Hz; 300W; 500VA
4) AC 120V; 3.5A; 50/60Hz; 210W; 350VA

Additional Manufacturing Plant: see above

(K751990)
contd.

Licensed Test mark:



Signature

Dipl.-Ing. A. Klinker
QA Certification Officer

Date of Issue

(day/mo/yr)

07/06/2010

Certificate



Certificate no.

CU 72101414 03

License Holder:

American Power Conversion
Holding Inc.
3F No. 205, Sec. 3, Beishin Rd.
231 Shindian City, Taipei
Taiwan - R.O.C.

Manufacturing Plant:

International Precision
Assemblies, Inc.
Lot 6 Blk 8, Phase II Peza
4106 Rosario Cavite
Philippines

Test report no.: USA-DS 31081589 001

Client Reference: Ms. Delia Lee

Tested to: UL 1778:1994 (R1.00)
CSA C22.2.107.1-01

Certified Product: Uninterruptible Power Supply Equipment

License Fee - Units

contd.

Additional Manufacturing Plant: see above

(K752451)

Licensed Test mark:



Signature

A handwritten signature in black ink, appearing to read "A. Klinker".

Dipl.-Ing. A. Klinker
QA Certification Officer

Date of Issue
(day/mo/yr)
07/06/2010

Certificate



Certificate no.

CU 72101414 04

License Holder:

American Power Conversion
Holding Inc.
3F No. 205, Sec. 3, Beixin Rd.
231 Xindian Dist., New Taipei City
Taiwan

Manufacturing Plant:

International Precision
Assemblies, Inc.
Lot 6 Blk 8, Phase II Peza
4106 Rosario Cavite
Philippines

Test report no.: USA-AK 31081589 002

Client Reference:

Tested to: UL 1778:1994 (R1.00)
CSA C22.2.107.1-01

Certified Product: Uninterruptible Power Supply Equipment

License Fee - Units

Change:

Address of License Holder: see above (K747834)
(was: 4F, No. 205, Sec. 3, Beishin Rd.,
Shindian City, Taipei, Taiwan)

Following Manufacturing Plant no longer valid:
American Power Conversion (India) Pvt., Ltd. (K751990)
187/3 & 188/3, Jigani, 562 106 anekal,
Bangalore, India

Appendix: 1, 1-5

Licensed Test mark:



Signature

A handwritten signature in black ink, appearing to read "F. Stöfel".

Dipl.-Ing. F. Stöfel
QA Certification Officer

Date of Issue

(day/mo/yr)
19/06/2012