

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7770-0328:0140

Page 1 of 1

CATEGORY: 7770 -- VALVES/SWITCHES

LISTEE: Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO 63042 United States
Contact: Bill Witherspoon (314) 595-6731 Fax (314) 595-6999
Email: BillW@pottersignal.com

DESIGN: Model VSRF-EX , 2" to 10", paddle type, open or closed circuit, water flow indicator. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 10A, 125, 250 VAC; 2.5A, 30 VDC
Max. 450 psi up to 8" size, max. 250 psi for 10" size

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as waterflow alarm switches for use with fire sprinkler systems. For vertical or horizontal installation in wet pipe sprinkler systems to produce alarm signals when circuited with a separately listed compatible fire alarm control unit. Suitable for use in hazardous locations, Class I, Group C and D; Class II, Group E, F and G.

NOTE:

*Rev 6-20-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**

Fire Engineering Division