

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7150-0785:0503 Page 1 of 1

CATEGORY: 7150 -- FIRE ALARM PULL BOXES

LISTEE: Cooper Wheelock Inc. 7246 16th St. E., Ste. 105, Sarasota, FL 34243
Contact: Tom Conover (941) 487-2336
Email: thomas.conover@cooperindustries.com

DESIGN: Models MPS-100, MPS-200, MPS-300, MPS-ISB, MPS-WP, noncoded manual pull stations.
MPS-100 includes a keylock without push bar.
MPS-200 includes a keylock with push bar.
MPS-300 includes a keylock without push bar.
MPS-ISB is a back box for interior use.
MPS-WP is a back box for exterior use.
Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 30 VDC, 125 VAC

INSTALLATION: In accordance with listee's printed installation, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as manual pull stations for use with separately listed and compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

XLF: 7150-1408:0107

10-16-2017 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division