

CERTIFICATE OF COMPLIANCE

Certificate Number 20140220- S2652
Report Reference S2652-19830531
Issue Date 2014-FEBRUARY-20

Issued to: COOPER WHEELLOCK INC
273 BRANCHPORT AVE
LONG BRANCH NJ 07740

**This is to certify that
representative samples of**

SPEAKERS AND AMPLIFIERS FOR FIRE-PROTECTIVE SIGNALING
SYSTEMS, SPEAKERS , SIGNALING APPLIANCES AND
EQUIPMENT FOR THE HEARING IMPAIRED


Fire Alarm and General Signaling Equipment:

Speakers - Models ET-1010 is for surface mounting only
Model ET-1010 may be used outdoors with WBB back box or WFP
flush plate with a 4" x 4" x 2-1/8" flush Backbox, found in File E55946,
Vol. 5, Sec. 1, Issued 1993-12-20.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL1480, Speakers for Fire Protective Signaling Systems
Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus

