

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7167-1273:0153 Page 1 of 1

CATEGORY: 7167 -- CONTROL UNIT (HOUSEHOLD)

LISTEE: Tyco Safety Products Canada Ltd. 3301 Langstaff Rd., Concord, Ontario L4K 4L2 Canada
Contact: Dan Nita (905) 760-3000 Fax (905) 760-3020
Email: dnita@tycoint.com

DESIGN: Models HS2128, HS2064, HS2032, HS2016 programable combination household fire and burglary alarm control units. Units contain an integral digital alarm communicator transmitter. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

Models HSM2300, HSM2204; Power Supply
Model HSM2108; Zone expander
Model HSM2208; PGM Output
Models HS2LCD, HS2LCDP, HS2ICN, HS2ICNP, HS2LED; Keypads
Models HS2LCDRF9, HS2LCDRFP9, HS2ICNRF9, HS2ICNRFP9; Keypads with RF receiver
*Model HS2LCDWFPV9, HS2LCDWFP9 and HS2LCDWF9; Wireless keypads.
Model HSM2HOST9; RF Receiver
PG9901, PG9911; Wireless Siren.

RATING: 16.5 Vac, 40 VA

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. The system must have the secondary power supply capable of operating the system for at least 24 hours (battery standby) in the normal condition and followed by not less than 5 minutes of alarm as required by code.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as combination household fire and burglary alarm control units for use with separately listed compatible initiating and indicating devices. Refer to listee's Installation Instructions Manual for details.

NOTE:

1. For household system, Fire Alarm Verification Feature (Delay of fire alarm signal) shall not be used in California.
2. Burglary and other non-fire functions were not examined.

*Rev 06-12-14 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2019**

Listing Expires **June 30, 2020**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division