

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

Page 1 of 1

**LISTING No.** 5278-2071:0100

**CATEGORY:** Carbon Monoxide Detectors

**LISTEE:** Macurco Inc., 1504 W 51st St., Sioux Falls, SD 57105  
Contact: Jonathon DeKam (605) 951-9643 Fax (605) 951-9616  
Email: jdekam@macurco.com

**DESIGN:** Model CM-E1 Carbon Monoxide Detector. Detector is intended for use with a listed alarm control panel. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 9 - 32 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, Model number, electrical rating and UL label.

**APPROVAL:** Listed as a Carbon Monoxide detector for use with listed alarm control panel.

**NOTE:** Carbon Monoxide detectors are not intended/suitable for fire and smoke detection.

7-29-11 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator  
Fire Engineering Division