

Category 6A 110 Punchdown Patch Panel Installation Procedure

1. General

- 1.1 These instructions detail the recommended installation procedures for terminating OCC's Category 6A DCC2488/1106APD and DCC4888/1106APD 110 Punchdown Patch Panels.

2. Contents

- 2.1 This package contains:
 - 1 - Category 6A 110 punchdown patch panel with strain relief bar(s)
 - 1 - Package of four (4) screws
 - Cable tie wraps

3. Tools Required

- 3.1 Tools required for this installation include:
 - 1 - Screw driver
 - 1 - 110 Punchdown tool

4. Instructions

- 4.1 Line up the holes at the corners of the panel with the corresponding mounting holes of the EIA compliant rack. Secure the panel with the four (4) screws provided. See Figure 1.

Note: A cable management panel should be placed between each patch panel for patch cord routing. OCC offers a full line of single and double-sided cable organizers. Please consult the OCC catalog for available options.



- 4.2 Carefully arrange, organize and bundle the UTP cable to be terminated at the patch panel. Be careful not to compress or deform the cable bundle when using cable ties. Check the cable number, patch panel, and termination modules to which the cable is to be terminated and direct cables accordingly using sound cable management procedures.


Caution - Cable Management precautions:

All effort should be made to eliminate cable stress caused by tension in suspended cable runs and cable bundles that are tightly cinched. Cable bend radius shall not be less than four times the cable diameter. When terminating horizontal cable, strip back the cable jacket only as much as needed to terminate on connecting hardware.

- 4.3 Measure and cut to length (plus 1 1/2" for stripping and termination) the cable to be terminated at the 110 module on the rear of the panel using sweeping bends. Strip the cable jacket back 1 1/2", being careful not to nick or scrape the conductor insulation. See Figure 2.



- 4.4 Position the cable at the appropriate 110 module and lace the conductors such that the cable jacket is positioned below the 110 being terminated. The white conductor of each pair shall be inserted to the left of the solid color. See Figures 3, 4, and 5.






Figure 4




Figure 6




Figure 5



Figure 7

CAUTION: The maximum untwist of a Category 6A cable pair is 1/2".

- 4.5 Using a 110 punchdown tool, make sure the cutoff blade is in the correct direction, then complete the termination by pressing on the handle of the punchdown tool until it toggles. The tool automatically terminates and cuts off the excess conductor. The installer may use the low or high impact setting on the tool.
- 4.6 Complete the termination of the remaining patch panel 110 modules following the above steps and dress each cable and secure in place.
- 4.7 Insert the strain relief bar(s) into the rear of the patch panel in the designated slots as shown. Using the cable tie wraps provided, secure the cables to the strain relief bar. Exercise care not to deform the cable jackets with cable ties. Cable ties must rotate freely about cable bundle. See Figures 6, 7, and 8.




Figure 8

4.8 Connecting patch cords between patch panels and electronic equipment is accomplished using OCC patch cords and cable organizers utilizing sound cable management practices.

Recommendations: In order to guarantee maximum performance from your OCC product, OCC recommends utilizing the OCC Category 6A patch cords for cross connect and station cords to connect the computer to the station outlet.

Thank you for purchasing Optical Cable Corporation's **Category 6A 110 Punchdown Patch Panel** product.