

Date : 2021/01/04

American Power Conversion Holdings
Inc., Taiwan Branch
5F., No. 189, Sec. 2, Jiuzong Rd.,
Neihu Dist., Taipei City 11494
Taiwan, R.O.C.
Attn: Ken Hsieh

Re. : CU US + Canada Certificate

Type of Equipment : Uninterruptible Power Supply
Model Designation : See Certificate
Certificate No. : CU 72205493 0001
File No. : 60433022 001
Engineer/Contact : Andreas Klinker
Standard(s) : UL 1778:2014 R10.17
CSA C22.2 NO. 107.3-14

Dear Madame or Sir,

The above referenced technical equipment has been tested and was found to be in compliance with the listed test requirement(s). Enclosed, please find the TUV Rheinland approval document No. CU 72205493 0001. It authorizes you to label the listed product(s) with the TUV Rheinland Mark identified in the approval document. For compliance, the Test Mark must be on the approved unit.

Your product is subject to regular factory follow-up inspections as well as annual certificate and factory registration fees.

In using the TUV Rheinland Mark you are obligated to comply with the TUV Rheinland of North America Service Agreement.

If we can be of any further assistance to you, please do not hesitate to contact us.

Sincerely yours,
Certification Body

H. Lin 
QA Certification Officer

Enclosure

Certificate



Certificate no.

CU 72205493 01

License Holder:

American Power Conversion Holdings Inc., Taiwan Branch
5F., No. 189, Sec. 2, Jiuzong Rd., Neihu Dist., Taipei City 11494
Taiwan

Manufacturing Plant:

Fuhong Precision Component (Bac Giang) Company Limited
Lot P (P1) and P (P2), Quang Chau Industrial Park, Viet Yen District, 220000 Bac Giang Province, Vietnam

Test report no.: USA-AK 60433022 001

Client Reference: 238039221/KH250520

Tested to: UL 1778:2014 R10.17
CSA C22.2 NO. 107.3-14

Certified Product: Uninterruptible Power Supply

License Fee - Units

Model Designation: 1) BR1300YYYYYYYY, 2) BR1500YYYYYYYY,
3) BX1300YYYYYYYY, 4) BX1500YYYYYYYY, 5) BN1250YYYYYYYY,
6) BN1350YYYYYYYY (Trademark : APC)

(Y can be any alphanumeric, +, *, #, _, - or blank)

Input Rating : AC 120V, 12A, 50/60Hz, 1Ø

Output Ratings : see Appendix (Constr. Data Form)

Protection Class : I

Rated Ambient Temperature : +40°C

Appendix: 1, 1-28

Licensed Test mark:

Date of Issue

(day/mo/yr)

04/01/2021

