




America

# CERTIFICATE

No. U8 060807 0023 Rev. 04

**Holder of Certificate:**    **AMERICAN POWER CONVERSION HOLDINGS INC.,**  
    **TAIWAN BRANCH**  
 5F., NO.189, SEC. 2, JIUZONG RD., NEIHU DIST.  
 11494 TAIPEI CITY  
 TAIWAN

**Certification Mark:**



**Product:**                            **Uninterruptible Powersupplies (UPS)**  
    **(Uninterruptible Power Supply)**

This product was voluntarily tested to the relevant safety requirements referenced on this certificate. It can be marked with the certification mark above. The mark must not be altered in any way. This product certification system operated by TÜV SÜD America Inc. most closely resembles system 3 as defined in ISO/IEC 17067. Certification is based on the TÜV SÜD "Testing and Certification Regulations". TÜV SÜD America Inc. is an OSHA recognized NRTL and a Standards Council of Canada accredited Certification body.

**Test report no.:**                            682101612207

**Date,**                            2021-12-02

( Bruce Zhang )



America

# CERTIFICATE

No. U8 060807 0023 Rev. 04

**Model(s):** **BN450Mxxxxxxxx, BE425Mxxxxxxxx**  
(‘x’ can be ‘0’ to ‘9’, ‘A’ to ‘Z’, ‘a’ to ‘z’, ‘-’, ‘\_’ or nil for marketing purpose)

**Brand Name:** **APC**

**Brand:**



**Tested according to:** **UL 1778:2014/R:2017-10**  
**CSA C22.2 No. 107.3:2014/R:2017-10**

## Parameters:

Ratings:

For model BE425Mxxxxxxxx:

Input: 120VAC, 6A, 50/60Hz, 1Ø

Battery backup outlets: 120VAC, 3.5A, 50/60Hz, 425VA/255W, 1Ø

Total outlet current: 6A

icc ≤ 1kA

For model BN450Mxxxxxxxx:

Input: 120VAC, 6A, 50/60Hz, 1Ø

Battery backup outlets: 120VAC, 3.8A, 50/60Hz, 450VA/255W, 1Ø

Total outlet current: 6A

icc ≤ 1kA

Protection Class: I

Degree of Protection: IP20